

RPZ valve: commissioning report form

Important information: Signed commissioning report to be left with the responsible person and received by Bristol Water within 10 working days of commissioning. Copy to be sent to waterregulations@bristolwater.co.uk or by post. Failure to provide the minimum information required could invalidate a test report. A copy of the RPZ approved installation method can be found here bristolwater.co.uk/water-regulations.

Company name & address where RPZ valve is installed

Postcode Tel no. Email

Name of the person responsible for the RPZ valve

Email Date of installation

Date of commissioning

Reason for commissioning

☐ New installation | ☐ Repair | ☐ Replacement of existing RPZ valve | ☐ Relocation of existing RPZ valve

Other RPZ valves on site? ☐ Yes ☐ No Total RPZ's on site

Change of test date request ☐ Yes ☐ No Requested test date

Consent to install granted ☐ Yes ☐ No ☐ N/A Consent ref no.

Existing valve details Manufacturer Model Serial no.

Size Date of last test Location of RPZ valve on site

Type of plant/equipment being supplied

New/replacement RPZ valve details Manufacturer Model

Serial no. Size Method of Supply ☐ Mains ☐ Storage

Name of installer/company (if known)

Commissioning result

☐ In service ☐ Not in service

Strainer present ☐ Yes ☐ No

Strainer clean ☐ Yes ☐ No

Unobstructed air break ☐ Yes ☐ No

Joints & seals watertight ☐ Yes ☐ No

Is valve location acceptable ☐ Yes ☐ No

Installed to AIM ☐ Yes ☐ No

RPZ valve Isolated ☐ Yes ☐ No

Proposed test date

Accessibility acceptable ☐ Yes ☐ No

Photos of installation ☐ Yes ☐ No

Tester's name Signature

Scheme name Membership no.

Address

Postcode Tel no. Email

Comments